



CENTRE LINE OF FITTINGS TO BE ON CENTRE LINE OF WINDOWS

SMOKE DETECTORS TO BE MIDWAY BETWEEN LIGHTING FITTINGS AND ON SAME CENTRE LINE

SMOKE DETECTORS TO BE MIDWAY BETWEEN LIGHTING FITTINGS AND ON SAME CENTRE LINE

UNIT J - GROUND FLOOR PLAN

Rev.	Date	Revisions
E	14.02.02	SMOKE DETECTORS ADDED IN MAIN OFFICE AREA AS IMPLICATES OF UNITS SHOWN ON POWER & ANCILLARY DRAWINGS
D	14.01.04	SMOKE DETECTORS ADDED
C	14.12.01	LIGHTING FITTINGS REFERENCES CHANGE TO A500W WITH REVISED A500W
B	18.10.2001	EMERGENCY FITTINGS, MAINWAY ALTERED
A	18.03.2001	EMERGENCY FITTINGS, MAINWAY ALTERED

BRUNEL
 ENGINEERING CONSULTANTS LTD
 1 Gloucester Row
 Clifton
 Bristol BS8 4AW
 TN 0117 973 0836 FX 0117 973 1897

Contract
REEDSPACE LIMITED
 PROPOSED OFFICE DEVELOPMENT
 EASTERN ROAD, BRACKNELL

Drawing Title
 UNIT J - GROUND FLOOR
 LIGHTING SERVICES
 15.2.02

Drawing Status
TENDER/CONTRACT

Date: DEC 2000 Scale: 1:50
 Drawing Number: 8193/JG/F/E2 Rev: E