

Certificate Reference:

1 DETAILS OF THE CLIENT

Client:

Address:

2 PURPOSE OF THE REPORT

Purpose for which this report is required:

3 DETAILS OF THE INSTALLATION

Installation Address:

Description of premises: Domestic Commercial Industrial Other:

Estimated age of electrical installation: years Evidence of alteration or additions: if yes, estimated age: years

Date of previous inspection:

Records of installation available: Electrical Installation Certificate No or previous Periodic Inspection Report No:

4 EXTENT OF THE INSTALLATION AND LIMITATIONS OF THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:

Agreed and operational limitations of the inspection and testing (include reasons and person agreed with):

The inspection has been carried out in accordance with BS 7671:2008, as amended to 2015. Cables concealed within trunking and conduits, under floors, in roof spaces and generally within the fabric of the building or underground, have not been inspected unless specifically agreed between the client and inspector prior to the inspection.

5 DECLARATION

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described on page 1 (see section 2), having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations (see section 7) and the attached schedules (see section 17), provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing (see section 4).

For the INSPECTION, TESTING AND ASSESSMENT of the report:
Name: Position: Signature: Date:

6 SUMMARY OF THE CONDITION OF THE INSTALLATION

See page 3 for a summary of the general condition of the installation in terms of electrical safety.

Overall assessment of the installation in terms of it's suitability for continued use*:

* An unsatisfactory assessment indicates that dangerous (Code C1) and/or potentially dangerous (Code C2) conditions have been identified.

8 RECOMMENDATIONS

Where the overall assessment of the suitability of the installation for continued use on page 1 is stated as 'UNSATISFACTORY', I/We recommend that any observations classified as 'Code 1 - Danger Present' or 'Code 2 - Potentially dangerous' are acted upon as a matter of urgency.

Investigation without delay is recommended for observations identified as 'FI - Further Investigation Required'.

Observations classified as 'Code 3 - Improvement recommended' should be given due consideration.

General condition of the installation in terms of electrical safety:

The installation is in a good condition and has minimal wear and tear to accessories. RCD protection not provided for any socket outlets and improvement is recommended.

9 NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than:

5 Years

(Enter interval in terms of years, months or weeks, as appropriate)

provided that any items in section 7 which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or require further investigation are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see section 7).

10 DETAILS OF THE ELECTRICAL CONTRACTOR

Trading Title:	PTS Compliance Ltd		
Address:	Unit 1 Brickfield Trading Estate, Brickfield Lane Chandlers Ford Hampshire	Registration Number:	7615249
	Postcode: SO53 4DR	Telephone Number:	0800 644 5400

11 SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Earthing Arrangements	Number and Type of Live Conductors				Nature of Supply Parameters			Supply Protective Device					
TN-S	N/A	1-phase (2 wire):	ac: <input checked="" type="checkbox"/> N/A	1-phase (3 wire):	N/A	2 pole:	N/A	Nominal voltage(s): U:	240 V	Uo:	230 V	BS(EN):	1361 Fuse HBC
TN-C-S	<input checked="" type="checkbox"/>	2-phase (3 wire):	N/A	3 pole:	N/A	Nominal frequency, f:	50 Hz	Type:	2	Prospective fault current, Ipf:	2.09 kA	Rated current:	100 A
TNC	N/A	3-phase (3 wire):	N/A	3-phase (4 wire):	<input checked="" type="checkbox"/> N/A	Other:	N/A	External earth fault loop impedance, Ze:	0.15 Ω	Short-circuit capacity:	33 kA	Number of supplies:	1
TT	N/A	Other:	N/A		Confirmation of supply polarity:	<input checked="" type="checkbox"/>							
IT	N/A												

12 PARTICULARS OF INSTALLATION REFERRED TO IN THE CERTIFICATE

Means of Earthing		Details of Installation Earth Electrode (where applicable)				
Distributor's facility:	<input checked="" type="checkbox"/>	Type:	N/A	Location:	N/A	
Installation earth electrode:	N/A	Resistance to Earth:	N/A Ω	Method of measurement:	N/A	
Maximum Demand (Load):	80 Amps	Protective measure(s) against electric shock:	ADS			
Main Switch / Switch-Fuse / Circuit-Breaker / RCD Type					If RCD main switch:	
BS(EN):	60947-3 Isolator	Current rating:	100 A	Supply conductors material:	Copper	
Number of poles:	3	Fuse/device rating or setting:	N/A A	Supply conductors csa:	25 mm ²	
		Voltage rating:	400 V	Rated residual operating current (IΔn):	N/A mA	
				Rated time delay:	N/A ms	
				Measured operating time (at IΔn):	N/A ms	
Earthing and Protective Bonding Conductors			Bonding of extraneous-conductive parts			
Earthing conductor			Connection/continuity verified:	<input checked="" type="checkbox"/>	To water installation pipes:	<input checked="" type="checkbox"/>
Conductor material:	Copper	csa:	16 mm ²		To oil installation pipes:	N/A
Main protective bonding conductors			Connection/continuity verified:	<input checked="" type="checkbox"/>	To lightning protection:	N/A
Conductor material:	Copper	csa:	10 mm ²		To other service(s):	N/A
				To structural steel:	N/A	N/A

13 INSPECTION SCHEDULE

Item	Description	Comment	Outcome
1.0	CONDITION/ADEQUACY OF DISTRIBUTOR'S/SUPPLY INTAKE EQUIPMENT		
1.1	Service cable	N/A	✓
1.2	Service head	N/A	✓
1.3	Distributor's earthing arrangements	N/A	✓
1.4	Meter tails – Distributor/Consumer	N/A	✓
1.5	Metering equipment	N/A	✓
1.6	Means of main isolation (where present)	N/A	✓
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR PARALLEL OR SWITCHED ALTERNATIVE SOURCES		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	N/A	N/V
2.1	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	N/A	N/A
3.0	AUTOMATIC DISCONNECTION OF SUPPLY		
3.1	Main earthing/bonding arrangements (411.3; Chap 54)		
3.1.1	Presence of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)	N/A	✓
3.1.2	Presence of installation earth electrode arrangement (542.1.2.3)	N/A	N/A
3.1.3	Adequacy of earthing conductor size (542.3; 543.1.1)	N/A	✓
3.1.4	Adequacy of earthing conductor connections (542.3.2)	N/A	✓
3.1.5	Accessibility of earthing conductor connections (543.3.2)	N/A	✓
3.1.6	Adequacy of main protective bonding conductor sizes (544.1)	N/A	✓
3.1.7	Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2)	N/A	✓
3.1.8	Accessibility of all protective bonding connections (543.3.2)	N/A	✓
3.1.9	Provision of earthing/bonding labels at all appropriate locations (514.13)	N/A	✓
3.2	FELV - requirements satisfied (411.7; 411.7.1)	N/A	N/A
4.0	OTHER METHODS OF PROTECTION (where the methods of protection listed below are employed, details should be provided on separate sheets)		
4.1	Non-conducting location (418.1)	N/A	N/A
4.2	Earth-free local equipotential bonding (418.2)	N/A	N/A
4.3	Electrical separation (Section 413; 418.3)	N/A	N/V
4.4	Double insulation (Section 412)	N/A	✓
4.5	Reinforced insulation (Section 412)	N/A	✓
5.0	DISTRIBUTION EQUIPMENT		
5.1	Adequacy of working space/accessibility to equipment (132.12; 513.1)	N/A	✓
5.2	Security of fixing (134.1.1)	N/A	✓
5.3	Condition of insulation of live parts (416.1)	N/A	✓
5.4	Adequacy/security of barriers (416.2)	N/A	✓
5.5	Condition of enclosure(s) in terms of IP rating etc (416.2)	N/A	✓
5.6	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	N/A	✓
5.7	Enclosure not damaged/deteriorated so as to impair safety (621.2(iii))	N/A	✓
5.8	Presence and effectiveness of obstacles (417.2)	N/A	✓
5.9	Presence of main switch(es), linked where required (537.1.2; 537.1.4)	N/A	✓

OUTCOMES													
Acceptable condition	TICK	Unacceptable condition	C1 or C2	Improvement recommended	C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A

14 INSPECTION SCHEDULE

Item	Description	Comment	Outcome										
5.10	Operation of main switch(es) (functional check) (612.13.2)	N/A	✓										
5.11	Manual operation of circuit-breakers and RCDs to prove disconnection (612.13..2)	N/A	✓										
5.12	Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check) (612.13.1)	N/A	✓										
5.13	RCD(s) provided for fault protection – includes RCBOs (411.4.9; 411.5.2; 531.2)	N/A	C3										
5.14	RCD(s) provided for additional protection, where required - includes RCBOs (411.3.3; 415.1)	N/A	C3										
5.15	Presence of RCD quarterly test notice at or near equipment, where required (514.12.2)	N/A	N/A										
5.16	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1)	N/A	✓										
5.17	Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14)	N/A	N/A										
5.18	Presence of alternative supply warning notice at or near equipment, where required (514.15)	N/A	N/A										
5.19	Presence of next inspection recommendation label (514.12.1)	N/A	✓										
5.20	Presence of other required labelling (please specify) (Section 514)	N/A	N/A										
5.21	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4, .5, .6; Sections 432, 433)	N/A	✓										
5.22	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.2)	N/A	✓										
5.23	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.11)	N/A	✓										
5.24	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	N/A	✓										
6.0	DISTRIBUTION CIRCUITS / FINAL CIRCUITS												
6.1	Identification of conductors (514.3.1)	N/A	✓										
6.2	Cables correctly supported throughout their run (522.8.5)	N/A	✓										
6.3	Condition of insulation of live parts (416.1)	N/A	✓										
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)	N/A	✓										
6.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	N/A	✓										
6.6	Cables correctly terminated in enclosures (Section 526)	N/A	✓										
6.7	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	N/A	✓										
6.8	Examination of cables for signs of unacceptable thermal or mechanical damage/deterioration (421.1; 522.6)	N/A	✓										
6.9	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	N/A	✓										
6.10	Adequacy of protective devices: type and rated current for fault protection (411.3)	N/A	✓										
6.11	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	N/A	✓										
6.12	Coordination between conductors and overload protective devices (433.1; 533.2.1)	N/A	✓										
6.13	Cable installation methods/practices with regard to the type and nature of installation and external influences (Section 522)	N/A	✓										
6.14	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	N/A	✓										
OUTCOMES													
Acceptable condition	TICK	Unacceptable condition	C1 or C2	Improvement recommended	C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A

15 INSPECTION SCHEDULE

Item	Description	Comment	Outcome										
6.15	Cables concealed under floors, above ceilings, in walls/partitions less than 50 mm from a surface, and in partitions containing metal parts:												
6.15.1	Installed in prescribed zones (see Section D. Extent and limitations) (522.6.202) or	N/A	✓										
6.15.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations) (522.6.204;)	N/A	✓										
6.16	Provision of additional protection by 30 mA RCD												
6.16.1	For circuits used to supply mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	N/A	C3										
6.16.2	For all socket-outlets of rating 20 A or less unless exempt (411.3.3)	N/A	C3										
6.16.3	For cables concealed in walls at a depth of less than 50 mm (522.6.202, .203)	N/A	C3										
6.16.4	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)	N/A	C3										
6.17	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	N/A	✓										
6.18	Band II cables segregated/separated from Band I cables (528.1)	N/A	✓										
6.19	Cables segregated/separated from non-electrical services (528.3)	N/A	✓										
6.20	Termination of cables at enclosures – identify/record numbers and locations of items inspected (Section 526)												
6.20.1	Connections under no undue strain (526.6)	N/A	✓										
6.20.2	No basic insulation of a conductor visible outside enclosure (526.8)	N/A	✓										
6.20.3	Connections of live conductors adequately enclosed (526.5)	N/A	✓										
6.20.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	N/A	✓										
6.21	Condition of accessories including socket-outlets, switches and joint boxes (621.2 (iii))	N/A	✓										
6.22	Suitability of circuit accessories for external influences (512.2)	N/A	✓										
6.23	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.2)	N/A	✓										
6.24	Adequacy of connections, including cpc's, within accessories and to fixed and stationary equipment – identify/record numbers and locations of items inspected (Section 526)	N/A	✓										
6.25	Presence, operation and correct location of appropriate devices for isolation and switching (537.2)	N/A	✓										
6.26	General condition of wiring systems (621.2(ii))	N/A	✓										
6.27	Temperature rating of cable insulation (522.1.1; Table 52.1)	N/A	✓										
7.0	ISOLATION AND SWITCHING												
7.1	Isolators (537.2)												
7.1.1	Presence and condition of appropriate devices (537.2.2)	N/A	✓										
7.1.2	Acceptable location – state if local or remote from equipment in question (537.2.1.5)	N/A	✓										
7.1.3	Capable of being secured in the OFF position (537.2.1.2)	N/A	✓										
7.1.4	Correct operation verified (612.13.2)	N/A	✓										
7.1.5	Clearly identified by position and/or durable marking (537.2.2.6)	N/A	✓										
7.1.6	Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.2.1.3)	N/A	✓										
7.2	Switching off for mechanical maintenance (537.3)												
7.2.1	Presence and condition of appropriate devices (537.3.1.1)	N/A	✓										
7.2.2	Acceptable location – state if local or remote from equipment in question (537.3.2.4)	N/A	✓										
OUTCOMES													
Acceptable condition	TICK	Unacceptable condition	C1 or C2	Improvement recommended	C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A

16 INSPECTION SCHEDULE

Item	Description	Comment	Outcome
7.2.3	Capable of being secured in the OFF position (537.3.2.3)	N/A	✓
7.2.4	Correct operation verified (612.13.2)	N/A	✓
7.2.5	Clearly identified by position and/or durable marking (537.3.2.4)	N/A	✓
7.3	Emergency switching/stopping (537.4)		
7.3.1	Presence and condition of appropriate devices (537.4.1.1)	N/A	✓
7.3.2	Readily accessible for operation where danger might occur (537.4.2.5)	N/A	✓
7.3.3	Correct operation verified (537.4.2.6)	N/A	✓
7.3.4	Clearly identified by position and/or durable marking (537.4.2.7)	N/A	✓
7.4	Functional switching (537.5)		
7.4.1	Presence and condition of appropriate devices (537.5.1.1)	N/A	✓
7.4.2	Correct operation verified (537.5.1.3; 537.5.2.2)	N/A	✓
8.0	CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)		
8.1	Condition of equipment in terms of IP rating etc (416.2)	N/A	✓
8.2	Equipment does not constitute a fire hazard (Section 421)	N/A	✓
8.3	Enclosure not damaged/deteriorated so as to impair safety (621.2(iii))	N/A	✓
8.4	Suitability for the environment and external influences (512.2)	N/A	✓
8.5	Security of fixing (134.1.1)	N/A	✓
8.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire (indicate extent of sampling in Section 4 of report)	N/A	✓
8.7	Recessed luminaires (e.g. downlighters)		
8.7.1	Correct type of lamps fitted	N/A	✓
8.7.2	Installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar (421.1.2)	N/A	✓
8.7.3	No signs of overheating to surrounding building fabric (559.4.1)	N/A	✓
8.7.4	No signs of overheating to conductors/terminations (526.1)	N/A	✓
9.0	LOCATION(S) CONTAINING A BATH OR SHOWER		
9.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)	N/A	N/A
9.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)	N/A	N/A
9.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)	N/A	N/A
9.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2008 (701.415.2)	N/A	N/A
9.5	Low voltage (e.g. 230 volt) socket-outlets sited at least 3 m from zone 1 (701.512.3)	N/A	N/A
9.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)	N/A	N/A
9.7	Suitability of accessories and controlgear etc. for a particular zone (701.512.3)	N/A	N/A
9.8	Suitability of current-using equipment for particular position within the location (701.55)	N/A	N/A
10.0	OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS List all other special installation or locations present, if any. (Record separately the results of particular inspections)		
10.1	N/A	N/A	N/A
10.2	N/A	N/A	N/A

OUTCOMES

Acceptable condition	TICK	Unacceptable condition	C1 or C2	Improvement recommended	C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
----------------------	------	------------------------	----------	-------------------------	----	-----------------------	----	--------------	-----	------------	-----	----------------	-----

17 SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Distribution board designation: **D.B. 1 (MEM 2)** Location: **cupboard on stairs** Type of Wiring O-Other: **N/A**

Circuit number and phase	Circuit designation	Type of wiring	Reference Method	Number of points served	Circuit conductors: csa		Max disconnect time permitted by BS7671 s	Overcurrent protective devices				RCD	Maximum Z _s permitted by BS7671 Ω	Circuit impedances (Ohms)					Insulation resistance		Polarity	Maximum measured earth fault loop impedance Z _s Ω	RCD			
					Live mm ²	cpc mm ²		BS(EN)	Type No	Rating A	Capacity kA			Operating current, I _{Δn} mA	Ring final circuits only (measured end to end)			All circuits (one column to be completed)		Live - Live MΩ			Live - Earth MΩ	Disconnection time at I _{Δn} ms	Disconnection time at 5I _{Δn} ms	Test button operation
															r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	R ₁ +R ₂	R ₂							
1 L1	GROUND FLOOR LIGHTING	B	B	6	1.5	1.5	0.4	60898	B	10	10	N/A	4.37	---	---	---	0.18	N/A	---	> 999	✓	0.47	---	---	N/A	
1 L2	FIRST FLOOR LIGHTING	B	B	7	1.5	1.5	0.4	60898	B	10	10	N/A	4.37	---	---	---	0.25	N/A	---	> 999	✓	0.41	---	---	N/A	
1 L3	GROUND FLOOR LIGHTING	B	B	8	1.5	1.5	0.4	60898	B	10	10	N/A	4.37	---	---	---	0.24	N/A	---	> 999	✓	0.41	---	---	N/A	
2 L1	GROUND FLOOR LIGHTING	B	B	7	1.5	1.5	0.4	60898	B	10	10	N/A	4.37	---	---	---	0.27	N/A	---	> 999	✓	0.46	---	---	N/A	
2 L2	FIRST FLOOR LIGHTING	B	B	6	1.5	1.5	0.4	60898	B	10	10	N/A	4.37	---	---	---	0.38	N/A	---	> 999	✓	0.48	---	---	N/A	
2 L3	SPARE	---	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	N/A	
3 L1	GROUND FLOOR LIGHTING	B	B	9	1.5	1.5	0.4	60898	B	10	10	N/A	4.37	---	---	---	0.30	N/A	---	> 999	✓	0.46	---	---	N/A	
3 L2	FIRST FLOOR LIGHTING	B	B	4	1.5	1.5	0.4	60898	B	10	10	N/A	4.37	---	---	---	0.35	N/A	---	> 999	✓	0.48	---	---	N/A	
3 L3	SPARE	---	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	N/A	
4 L1	GROUND FLOOR LIGHTING	B	B	7	1.5	1.5	0.4	60898	B	10	10	N/A	4.37	---	---	---	0.36	N/A	---	> 999	✓	0.47	---	---	N/A	

18 BOARD CHARACTERISTICS

APPLIES WHEN THE BOARD IS NOT CONNECTED TO THE ORIGIN OF THE INSTALLATION

Supply to this distribution board is from: **N/A** No of phases: **N/A** Confirmation of supply polarity: **N/A**
 Overcurrent protective device for the distribution circuit: BS(EN): **N/A** Rating: **N/A A** Nominal Voltage: **N/A V** Z_s: **N/A Ω** Ip_f: **N/A kA**
 RCD BS(EN): **N/A** No of poles: **N/A** Rating: **N/A mA** Disconnection time at In: **N/A ms** Disconnection time at 5I_n: **N/A ms**

19 DETAILS OF TEST INSTRUMENTS

Details of Test Instruments used (state serial and/or asset numbers):

Multi-functional: **101710217** Insulation resistance: **101710217** Continuity: **101710217**
 Earth electrode resistance: **101710217** Earth fault loop impedance: **101710217** RCD: **N/A**

20 TESTED BY

Name: **Lewis Crawford** Position: **Engineer** Signature:  Date: **16/08/2018**

SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Distribution board designation: D.B. 1 (MEM 2) Location: cupboard on stairs Type of Wiring O-Other: N/A

Circuit number and phase	Circuit designation	Type of wiring	Reference Method	Number of points served	Circuit conductors: csa		Max disconnect time permitted by BS7671 s	Overcurrent protective devices				RCD	Maximum Z _s permitted by BS7671 Ω	Circuit impedances (Ohms)					Insulation resistance		Polarity	Maximum measured earth fault loop impedance Z _s Ω	RCD									
					Live mm ²	cpc mm ²		BS(EN)	Type No	Rating A	Capacity kA			Operating current, I _{Δn} mA	Ring final circuits only (measured end to end)			All circuits (one column to be completed)		Live - Live MΩ			Live - Earth MΩ	Disconnection time at I _{Δn} ms	Disconnection time at 5I _{Δn} ms	Test button operation						
															r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	R ₁ +R ₂	R ₂													
					---	---		---	---	---	---			---	---	---	---	---	---	---			---	---	---	---	---	---	---			
4 L2	SPARE	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	---	---	---	---	---	---	---	---	N/A
4 L3	SPARE	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	---	---	---	---	---	---	---	---	N/A
5 L1	FLOOR BOXES	F	B	3	6	6	0.4	60898	B	32	10	N/A	1.37	---	---	---	0.17	N/A	---	> 999	✓	0.30	---	---	---	---	---	---	---	---	N/A	
5 L2	FLOOR BOXES	F	B	6	6	6	0.4	60898	B	32	10	N/A	1.37	---	---	---	0.15	N/A	---	> 999	✓	0.27	---	---	---	---	---	---	---	---	---	N/A
5 L3	GROUND FLOOR SOCKETS	B	B	3	4	4	0.4	60898	B	32	10	N/A	1.37	---	---	---	0.27	N/A	---	> 999	✓	0.46	---	---	---	---	---	---	---	---	---	N/A
6 L1	GROUND FLOOR SOCKETS	B	B	3	4	4	0.4	60898	B	32	10	N/A	1.37	---	---	---	0.14	N/A	---	> 999	✓	0.27	---	---	---	---	---	---	---	---	---	N/A
6 L2	FS GF INTRUDER ALARM	B	B	1	1.5	1.5	0.4	60898	B	6	10	N/A	7.28	---	---	---	0.11	N/A	---	> 999	✓	0.22	---	---	---	---	---	---	---	---	---	N/A
6 L3	FLOOR BOXES	F	B	6	6	6	0.4	60898	B	32	10	N/A	1.37	---	---	---	0.16	N/A	---	> 999	✓	0.23	---	---	---	---	---	---	---	---	---	N/A
7 L1	FLOOR BOXES	F	B	3	6	6	0.4	60898	B	32	10	N/A	1.37	---	---	---	0.18	N/A	---	> 999	✓	0.29	---	---	---	---	---	---	---	---	---	N/A
7 L2	SPARE	---	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	---	---	---	---	---	---	---	N/A
7 L3	FIRST FLOOR SOCKETS	B	B	2	4	4	0.4	60898	B	32	10	N/A	1.37	---	---	---	0.08	N/A	---	> 999	✓	0.24	---	---	---	---	---	---	---	---	---	N/A
8 L1	SPARE	---	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	---	---	---	---	---	---	---	N/A
8 L2	SPARE	---	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	---	---	---	---	---	---	---	N/A
8 L3	SPARE	---	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	---	---	---	---	---	---	---	N/A
9 L1	SPARE	---	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	---	---	---	---	---	---	---	N/A
9 L2	SPARE	---	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	---	---	---	---	---	---	---	N/A
9 L3	SPARE	---	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	---	---	---	---	---	---	---	N/A
10 L1	SPARE	---	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	---	---	---	---	---	---	---	N/A
10 L2	SPARE	---	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	---	---	---	---	---	---	---	N/A

SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Distribution board designation:

D.B. 1 (MEM 2)

Location:

cupboard on stairs

Type of Wiring
O-Other:

N/A

Circuit number and phase	Circuit designation	Type of wiring	Reference Method	Number of points served	Circuit conductors: csa		Max disconnect time permitted by BS7671 s	Overcurrent protective devices				RCD Operating current, IΔn mA	Maximum Zs permitted by BS7671 Ω	Circuit impedances (Ohms)					Insulation resistance		Polarity ✓	Maximum measured earth fault loop impedance Zs Ω	RCD							
					Live mm ²	cpc mm ²		BS(EN)	Type No	Rating A	Capacity kA			Ring final circuits only (measured end to end)			All circuits (one column to be completed)		Live - Live MΩ	Live - Earth MΩ			Disconnection time at IΔn ms	Disconnection time at 5IΔn ms	Test button operation ✓					
														r1 (Line)	rn (Neutral)	r2 (cpc)	R1+R2	R2												
10 L3	SPARE	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	---	---	N/A	---	---	---	N/A
11 L1	SPARE	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	---	---	---	---	---	---	N/A
11 L2	SPARE	---	---	---	---	---	---	---	---	---	N/A	N/A	---	---	---	---	N/A	---	---	---	---	---	---	---	---	---	---	---	---	N/A
11 L3	BELL TRANSFORMER	A	B	1	1.5	1.5	0.4	60898	B	6	10	N/A	7.28	---	---	---	0.11	N/A	---	> 999	✓	0.22	---	---	---	---	---	---	---	N/A
12 TP	D.B 2	A	B	1	10	10	0.4	60898	C	63	10	N/A	0.35	---	---	---	0.01	N/A	---	> 999	✓	0.23	---	---	---	---	---	---	---	N/A

SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Distribution board designation: D.B. 2 (MEM2) Location: cupboard on stairs Type of Wiring O-Other: N/A

Circuit number and phase	Circuit designation	Type of wiring	Reference Method	Number of points served	Circuit conductors: csa		Max disconnect time permitted by BS7671 s	Overcurrent protective devices				RCD	Maximum Z _s permitted by BS7671 Ω	Circuit impedances (Ohms)					Insulation resistance		Polarity	Maximum measured earth fault loop impedance Z _s Ω	RCD			
					Live mm ²	cpc mm ²		BS(EN)	Type No	Rating A	Capacity kA			Operating current, I _{Δn} mA	Ring final circuits only (measured end to end)			All circuits (one column to be completed)		Live - Live MΩ			Live - Earth MΩ	Disconnection time at I _{Δn} ms	Disconnection time at 5I _{Δn} ms	Test button operation
															r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	R ₁ +R ₂	R ₂							
1 L1	FLOOR BOXES	F	E	3	6	6	0.4	60898	B	32	10	N/A	1.37	---	---	---	0.21	N/A	---	> 999	✓	0.38	---	---	N/A	
1 L2	FLOOR BOXES	F	E	6	6	6	0.4	60898	B	32	10	N/A	1.37	---	---	---	0.20	N/A	---	> 999	✓	0.35	---	---	N/A	
1 L3	FLOOR BOXES	F	E	6	6	6	0.4	60898	B	32	10	N/A	1.37	---	---	---	0.17	N/A	---	> 999	✓	0.29	---	---	N/A	
2 L1	FLOOR BOXES	F	E	3	6	6	0.4	60898	B	32	10	N/A	1.37	---	---	---	0.29	N/A	---	> 999	✓	0.56	---	---	N/A	
2 L2	SPARE	---	---	---	---	---	---	---	---	---	---	---	N/A	---	---	---	---	N/A	---	---	---	---	---	---	N/A	
2 L3	SPARE	---	---	---	---	---	---	---	---	---	---	---	N/A	---	---	---	---	N/A	---	---	---	---	---	---	N/A	
3 TP	SPARE	---	---	---	---	---	---	---	---	---	---	---	N/A	---	---	---	---	N/A	---	---	---	---	---	---	N/A	
4 TP	SPARE	---	---	---	---	---	---	---	---	---	---	---	N/A	---	---	---	---	N/A	---	---	---	---	---	---	N/A	

BOARD CHARACTERISTICS

APPLIES WHEN THE BOARD IS NOT CONNECTED TO THE ORIGIN OF THE INSTALLATION

Supply to this distribution board is from: D.B 1 No of phases: 3 Confirmation of supply polarity:

Overcurrent protective device for the distribution circuit: BS(EN): 60898 MCB - Type C Rating: 63 A Nominal Voltage: 400 V Z_s: 0.23 Ω Ip_f: 1.94 kA

RCD BS(EN): N/A No of poles: N/A Rating: N/A mA Disconnection time at In: N/A ms Disconnection time at 5In: N/A ms

DETAILS OF TEST INSTRUMENTS

Details of Test Instruments used (state serial and/or asset numbers):

Multi-functional: 101710217 Insulation resistance: 101710217 Continuity: 101710217

Earth electrode resistance: 101710217 Earth fault loop impedance: 101710217 RCD: N/A

TESTED BY

Name: Lewis Crawford Position: Engineer Signature: Date: 16/08/2018

CONTINUATION FOR GENERAL COMMENTS

GENERAL COMMENTS

General Comments for the Installation or Inspection of the report:

No live to neutral insulation resistance testing carried out.

ELECTRICAL INSTALLATION CONDITION REPORT GUIDANCE FOR RECIPIENTS

(to be appended to the Report)

This Report is an important and valuable document which should be retained for future reference.

The purpose of this Condition Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in satisfactory condition for continued service (see Section 7). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger.

The person ordering the Report should have received the "original" Report and the inspector should have retained a duplicate.

The "original" Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.

Where the installation incorporates a residual current device (RCD) there should be a notice at or near the device stating that it should be tested quarterly. For safety reasons it is important that this instruction is followed.

Section 4 (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in section 4 - Extent and Limitations on page 1.

For items classified in the observations as C1 ("Danger present"), the safety of those using the installation is at risk, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work immediately.

For items classified in the observations as C2 ("Potentially dangerous"), the safety of those using the installation may be at risk and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where it has been stated that an observation requires further investigation (code FI) the inspection has revealed an apparent deficiency which may result in a code of C1 or C2, and could not, due to the extent or limitations of the inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section 8 - Recommendations).

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated on page 3 under section 10 'Next Inspection', and on a label at or near to the consumer unit / distribution board.